



Date Adopted: 11/27/84

Date Revised: 11/27/84

Date Reviewed: 12/20/16

Policy 109
Standby Electric Service

POLICY:

The Cooperative acknowledges the need for and presence of standby electrical plants at places of business or residences of members.

Concerning the use of such generators by its members, the following safety equipment is required:

1. A double-throw switch must be installed under the meter.
2. The generating equipment must be grounded to the Cooperative's pole ground.

RESPONSIBILITY:

Manager, Operations Manager and Member

PROCEDURE:

As outlined in the above written policy.